

SUMMARY OF THE TEST REPORT No. 0837/09

Client:

GOLDEN DOOR ABEE

PERFORMED TESTS:

**Air permeability (EN 1026 - UNI EN 12207)
Watertightness (EN 1027 - UNI EN 12208)
Resistance to wind load (EN 12211 - UNI EN 12210)**

Sample dimensions:

Length of opening joints: 6,10 m
Overall area: 2,09 m²


PRODUCT TRADE NAME:

PORTA BLINDATA

TEST RESULTS:


**AIR PERMEABILITY EN 1026 AND UNI EN 12207: 4
WATERTIGHTNESS EN 1027 AND UNI EN 12208: 8A
RESISTANCE TO WIND LOAD EN 12211 AND UNI EN 12210: C5**

General Manager
Stefano Mora



All test results, with experimentally measured values, listed in this test report summary are included in the test report No. 0837/09 dated 30/11/2009 issued by this Laboratory.

Technical Manager
Ing. Antonio D'Albo



Correggio, 30/11/2009